



Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory, Kurukshetra.
 Jal Bhawan Sector-10 Kkr. Email id: -chemist.kkra@gmail.com.

Test Report

URL No. :	TC4560260000287 F	Sample Collected on Date :	01/06/2026
Test Report No.:	KKR/ 01715/06/2026	Sample Received on Date :	01/06/2026
Sender Address:	Daffodil Public School, Ismailabad, Kurukshetra ,	Sample Location :	Daffodil Public School, Ismailabad, Kurukshetra,
Customer Reference No.:	0	Sample Quantity :	1 Ltr.
Sample Description :	Water	Date of Analysis Started :	01/06/2026
Sample Type :	Physico-Chemical Analysis	Date of Analysis Completed:	03/06/2026
Memo No.:	1022 Date: 03/06/2026	Date of issue :	03/06/2026


RESULTS						
S.No.	Parameter	Protocol used	Result	IS: 10500:2012(Second revision)		Unit
				Acceptable Limit	Permissible limit in the absence of alternate source	
1	Colour	IS 3025Part-4: 2021	<05	5	15	Hazen
2	Odour	IS 3025Part-5: 2018	Agreeable	Agreeable	Agreeable	-
3	Taste	IS 3025Part-8: 2023	Agreeable	Agreeable	Agreeable	-
4	Total Dissolve Solids (180°C)	IS 3025Part-16: 2023	368	500	2000	mg/L
5	Total Hardness (as CaCo3)	IS 3025Part-21: 2009	125	200	600	mg/L
6	Calcium (as Ca)	IS 3025Part-40: 1991 RA 2019	28.05	75	200	mg/L
7	Magnesium (as Mg)	IS 3025Part-46: 2023	13.36	30	100	mg/L
8	Total Alkalinity (as CaCo3)	IS 3025Part-23: 2023	275	200	600	mg/L
9	Chloride (as Cl)	IS 3025Part-32: 1988 RA 2019	15.03	250	1000	mg/L
10	Sulphate (as So4)	IS 3025 Part-24 Sec.1 :2022	45.1	200	400	mg/L
11	Fluoride (as F)	IS 3025Part-60: 2023	0.41	1.0	1.5	mg/L
12	Iron (as Fe)	IS 3025 Part-53: 2024	0.14	1.0	No Relaxation	mg/L
13	Nitrate (as NO3)	APHA 4500-NO3B	1.91	45	No Relaxation	mg/L
14	pH (25°C)	IS 3025Part-11: RA 2022	8.14	6.5 to 8.5	No Relaxation	-
15	Turbidity	APHA2130 B 2023	BDL	1	5	NTU

Notes:-

- The Results given above are related to the sample as received and tested in PHED Lab, Kurukshetra.
- Reliability of sample lies with the sender. Sample not collected by this Laboratory and sample is collected by sender himself/ herself.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
- Abbreviation used (mg/L = milligram per liter, BDL= Below Detection Limit, APHA= American Public Health Association, IS= Indian Standard, NA= Not Applicable, NTU= Nephelometric Turbidity unit, RA= Reaffirmed)
- Test Performed at Temperature = 25 ± 5° C and Humidity Condition Limit: 50 ± 20%.

Reviewed By

(Nisha Saini)
 Authorized Signatory/Chemist
 PHED Water Testing Laboratory,
 Kurukshetra



MANAGER
DAFFODIL EDUCATION SOCIETY
ISMALABAD (KKR.)

Principal
Daffodil Public School
Ismailabad (Kurukshetra)

End of the Report

PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, KURUKSHETRA

Website :- <https://phedharyana.gov.in/>

Memò No:- 1020

Date:- 03/06/2026

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KKR/01718/6/2026	Sample Details	Date & Time
Sample Classification:	Private	Collected By	Vinay,7015268206
Sender:	Daffodil Public School	Collection Date	01/06/2026 at 15:24
Location :-	, Daffodil Public School	Received at lab	01/06/2026 at 15:34
Latitude :-	76.670699	Tested at Lab	03/06/2026
Longitude :-	30.136387		

Test Result (As Per BIS 10500 :2012)				
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"




NISHA SAINI, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY KURUKSHETRA
email:-chemist.kkra@phedharyana.gov.in

-----End of Report-----.


MANAGER
DAFFODIL EDUCATION SOCIETY
ISMAILABAD (KKR.)


Principal
Daffodil Public School
Ismailabad (Kurukshetra)

Annexure-C

Office of Civil Surgeon, Kurukshetra

No. GH/2026/ 1247

Date: 08/06/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by MO PHC Ismailabad, Distt. Kurukshetra from Health Department inspected the building of Daffodil Public School, Patiala Road, Ismailabad District Kurukshetra on 05-06-2026 and on the basis of water test report bearing No. 1020 dated 03-06-2026 of PHED Lab KKR certified that Daffodil Public School, Patiala Road, Ismailabad District Kurukshetra has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt. This certificate is valid till 07-06-2027.

Signature with seal: Dy. Civil Surgeon (Health)

Name :Kurukshetra.....

Designation : Dy. Civil Surgeon, Kurukshetra

Name & Address of the Office / Department:

O/o Civil Surgeon, Kurukshetra

To
Principal,
Daffodil Public School, Patiala Road, Ismailabad
District Kurukshetra

MANAGER
DAFFODIL EDUCATION SOCIETY
ISMAILABAD (KKR.)

Principal
Daffodil Public School
Ismailabad (Kurukshetra)